



April 29, 2019

Environmental Maintenance Engineers, Inc.
25851 Trowbridge Street
Inkster, MI 48141

RE: Environmental Services associated with Post Abatement Sampling at 2920 Baldwin, Detroit, MI 48214. ETC Job #: 220707. Client Job # 19-212A.

Dear Client:

Pursuant to your request, Environmental Testing & Consulting, Inc. (ETC) conducted post abatement air sampling on the 1st Floor and in the Basement of the Vacant Residence located at 2920 Baldwin, Detroit, MI 48214 on April 26, 2016. This type of sampling is performed after asbestos abatement activities are conducted. The purpose of this sampling is to confirm if the air in the work area is acceptable to allow building occupants to reoccupy the area.

The results of this sampling are enclosed in this report. Please note that these samples were below the following regulated clearance level of 0.050 f/cc as required by the Michigan Occupational Safety & Health Administration (MIOSHA).

Also, enclosed are copies of the data sheets, daily field notes, and a map of sample locations.

Thank you for selecting ETC. It has been a pleasure working with you. Further environmental services are available upon request. If you have any questions regarding this report please refer to the daily project log or contact me at (734) 955-6600.

Sincerely,
Environmental Testing & Consulting, Inc.

A handwritten signature in black ink, appearing to read "Bernard Robinson", is written over a horizontal line.

Bernard Robinson
Industrial Hygienist

38900 West Huron River Drive, Romulus, MI 48174
PHONE: (734) 955-6600 FAX: (734) 955-6604
WEBSITE: www.2etc.com

Asbestos Abatement Air Monitoring Project



**the
ETC
group**

environmental testing
project management
laboratory analysis
professional training

Client: Environmental Maintenance Engineers, Inc

Contractor: EME

Facility: 2920 Baldwin, Detroit, MI 48214

ETC Project #: 220707

Date: 4/26/2019

Hygienist: Bernard Robinson

Areas of Work: 1st Floor - Bathroom FS6 , Basement, Exterior House

FIELD DATA SHEET

Sample ID (below)	Sampling Time		Elapsed Time (min)	Sampling Data		Flow Rate (lpm)	Volume (L)	Actual Results (f/cc)	8 Hour TWA (f/cc)	Description and Location
	Start	Stop		Fibers	Fields					
FB1				0.0	100					FIELD BLANK
FB2				0.0	100					FIELD BLANK
PA1	13:48	15:30	102	14.0	100	14.7	1499.40	0.005		FS6 bathroom first floor at just inside door on east wall
PA2	13:48	15:30	102	11.0	100	14.7	1499.40	0.004		in center of basement next to octopus furnace

AA- Ambient Air
BL- Baseline
CS-Contiguous

EA- Exhaust Air, EX- Excursion
PA- Post Abatement
PP- Personal/Post Abatement

PS- Personal
WA- Work Area
WP- Work Area/Post Abatement

Asbestos Abatement Air Monitoring Project

Summary of Daily Activities



Client: Environmental Maintenance Engineers, Inc

Contractor: EME

Competent Person: Daniel Walerski

Facility: 2920 Baldwin, Detroit, MI 48214

ETC Project #: 220707

Date: 4/26/2019

Areas of Work: 1st Floor - Bathroom FS6 , Basement, Exterior House

Work Area	Materials Removed	Approx. Total Amount	Friable/ Non-Friable	Removal Technique	% Done	Clearance Level	PCM/ TEM	Aggressive Clearance Required	Aggressive Clearance Performed	Pass/ Fail
1st Floor - Bathroom FS6	Floor tile	45sqft	N-Friable	CB	100%	0.050	PCM	NO	NO	Pass
Basement	Duct wrap	30sqft	Friable	CB	100%	0.050	PCM	NO	NO	Pass
Exterior House	Caulk	480 lft	N-Friable	CB	100%	NA	NA	NA	NA	NA

13:30 I, Bernard Robinson, here to perform asbestos abatement air monitoring at 2920 Baldwin, Detroit, MI 48214 for Environmental Maintenance Engineers, Inc contractor, EME.

I talked to Dan from EME. Crew not yet ready for me. I'm going to start my paper work and get my stuff ready to go for when EME is ready.

13:48 I stated PA samples at 13:48 and checked survey. I did a visual inspection for all acm material that was removed. I returned to truck to finish maps and paper work

14:30 Dumpster pick up and EME is loading equipment. All my paperwork is up to date for this project.


15:30 I pulled all samples and headed to truck to mount and read samples.

16:00 All samples mounted and read. I hung re-occupancy form on front door. All pumps are gathered and house is locked up. I am leaving site.

This job is 100% completed.

Documented By
Bernard Robinson

Asbestos Abatement Air Monitoring Project



the
ETC
group

environmental testing
project management
laboratory analysis
professional training

Client: Environmental Maintenance Engineers, Inc

Contractor: EME

Facility: 2920 Baldwin, Detroit, MI 48214

ETC Project #: 220707

Date: 4/26/2019


Hygienist: Bernard Robinson

Areas of Work: 1st Floor - Bathroom FS6 , Basement, Exterior House

General Diagram of Work Areas



NOT TO SCALE



**the
ETC
group**

environmental testing
project management
laboratory analysis
professional training

Asbestos Abatement Air Monitoring Project

Client: Environmental Maintenance Engineers, Inc

Contractor: EME

Facility: 2920 Baldwin, Detroit, MI 48214


ETC Project #: 220707

Date: 4/26/2019

Hygienist: Bernard Robinson

Areas of Work: 1st Floor - Bathroom FS6 , Basement, Exterior House

General Diagram of Work Areas



Not to scale

Asbestos Abatement Air Monitoring Project



**the
ETC
group**

environmental testing
project management
laboratory analysis
professional training

Client: Environmental Maintenance Engineers, Inc

Contractor: EME

Facility: 2920 Baldwin, Detroit, MI 48214


ETC Project #: 220707

Date: 4/26/2019

Hygienist: Bernard Robinson

Areas of Work: 1st Floor - Bathroom FS6 , Basement, Exterior House

General Diagram of Work Areas



Work area

Basement

S
E W
N

Not to scale